

4701 New Jersey Avenue
Wildwood, NJ 08260
Phone: 609-854-3311
Fax: 609-854-4323
www.deblasioassoc.com

DEBLASIO & ASSOCIATES

FAX/EMAIL

Cover Letter

TO: All Bidders FROM: Marc DeBlasio, P.E., P.P., C.M.E.

FAX: _____ **PAGES:** 3

PHONE: _____ DATE: January 8, 2026

RE: Water System Improvements and Roadway CC: Ed Stinson, P.E., City Engineer (via email)
Reconstruction of Bayshore Avenue from Christine Murray, Acting City Clerk (via
38th Street to the Lighthouse Circle email)
BC-C-009

Urgent For Review Please Comment Please Reply Please Recycle

Comments: Please find enclosed Addendum No. 1. Please acknowledge receipt.

ADDENDUM NO. 1

**To All Bidders of
Water System Improvements and Roadway Reconstruction of Bayshore Avenue
from 38th Street South to the Lighthouse Circle
City of Brigantine
Atlantic County, New Jersey
D&A Project #: BC-C-009**

You are hereby notified in accordance with ITB – Section 3.0 – Interpretation and Addenda of the above captioned project that the following has been issued to clarify the meaning of the plans and specifications and that the conditions and specifications set forth in said addenda are to be original contract documents.

Please be advised of the following:

1. Please substitute Bid Form Page PS-29 (Rev.) for Bid Form Page PS-29.

The following question has been submitted.

- Q. Is there a settlement period for newly installed pipe work?
- A. Yes, the required settlement period shall be 30 days unless otherwise waived by the Engineer.

THIS ADDENDUM MUST BE RETURNED WITH ALL BIDS. THE FAILURE TO RETURN THIS SIGNED RECEIPT WITH THE CONTRACT FORMS WILL RESULT IN A NON-RESPONSIVE BID

I acknowledge receipt of this addendum.

Signature

Company

Item	Quantity	Units	Description	Unit Price	Amount
23	20	L.F.	TRAFFIC MARKINGS LINES, 12"	\$ _____	\$ _____
24	2	UNIT	SANITARY SEWER SERVICE LATERALS, PVC SDR 35	\$ _____	\$ _____
25	1,200	C.Y.	SELECT FILL	\$ _____	\$ _____
26	5	UNIT	UTILITY CROSSINGS (IF & WHERE DIRECTED)	\$ _____	\$ _____
27	3	UNIT	FIRE HYDRANT ASSEMBLIES, COMPLETE	\$ _____	\$ _____
28	5	UNIT	8"X6" WET TAP ASSEMBLY	\$ _____	\$ _____
29	3	UNIT	RESET EXISTING CASTING	\$ _____	\$ _____
30	200	L.F.	6" DUCTILE IRON WATER MAIN, CLASS 52	\$ _____	\$ _____
31	5	UNIT	6"X4" DUCTILE IRON REDUCER	\$ _____	\$ _____
32	5	UNIT	CONNECT TO EXISTING WATER MAIN	\$ _____	\$ _____
33	4	UNIT	4" INSERTION VALVE	\$ _____	\$ _____
34	2	UNIT	WATER SERVICES, 1" COMPLETE (IF & WHERE DIRECTED)	\$ _____	\$ _____
35	1,200	DOLLAR	FUEL PRICE ADJUSTMENT	\$1.00	\$1,200.00
36	2,100	DOLLAR	ASPHALT PRICE ADJUSTMENT	\$1.00	\$2,100.00
37	25,000	DOLLAR	ALLOWANCE UNFORESEEN ITEMS	\$1.00	\$25,000.00

Total Amount Bid Based on Estimated Quantities 1 to 37, Inclusive: \$ _____

Total Amount Bid Based on Estimated Quantities 1 to 37, Inclusive (Written): _____

DOLLARS

_____ BIDDER _____ BIDDER'S SIGNATURE

_____ DATE _____